



This project has received funding from the European Union's Horizon 2020 research and innovation programme under grant agreement No 792059



Oct. 29th

System Design of PV utility scale

(9:30-10:00)

GLOBAL OPTIMIZATION OF
INTEGRATED **PHOTOVOLTAIC** SYSTEM
FOR LOW ELECTRICITY COST





System Design of PV utility scale

Enel Green Power S.p.A.



Agenda

1 Site Preliminary Analysis


2 Conceptual Design

3 Mitigation of Energy Losses



Site Preliminary Analysis



Land surface evaluation



KMZ file of the site:

- Land area;
- Exclusions;
- Interconnection point.

Slope analysis:





Site Preliminary Analysis

Local Meteo Parameters – Meteo Provider



SOLARGIS Prospect MAP PROJECTS COMPARE PROJECT DETAIL

Active projects

Search projects or locations

Roma

Viale dell'Oceano Pacifico, Roma, Lazio, Italia
41.816509, 12.45961

PV system configuration not set

MAP DATA	PROJECT DATA
ELE	9 m
<input checked="" type="checkbox"/> PVOUT csi	1529 kWh/kWp
GHI	1608 kWh/m ²
DNI	1692 kWh/m ²
DIF	620 kWh/m ²

Monthly/hourly meteo data:

- Global Irradiation;
- Diffuse Irradiation;
- Albedo;
- Air Temperature;
- Wind Speed;
- Rainfall rate;
- Horizon file.

Meteonorm 7 v7.3.4

File Luoghi Strumenti Aiuto

Roma

Modifiche & importazione dati

Modifiche

Roma -26.6°N / 148.8°E, 299 m

Stazione meteo

Generale

Correzione delle misurazioni dell'irraggiamento globale

Usa dati dell'irraggiamento globale puliti (escludendo effetti dell'orizzonte)
 Usa dati dell'irraggiamento globale originali (incluso effetti dell'orizzonte)
 Applicabile soltanto a stazioni meteo con orizzonti alti.

Specifiche del luogo

Orientamento del piano

Azimuth °

Inclinazione °

Albedo

Automatico

Personalizzato

Orizzonte

Nessuno
 Personalizzato

Torbidità atmosferica

Interpolato
 Stazione Aeronet più vicina
 Personalizzato

Importazione dati / scarica le serie temporali

Valori mensili... Valori giorno/ora...


spostazioni di calcolo 1991-2010

formato d'uscita User defined

ultimati ed esportazione

Project horizon and sunpath

Default horizon




Modify horizon




Site Preliminary Analysis

Local Meteo Parameters – Ground Measurements



Central meteorological tower

Pyranometer



SPN1



- Global (Total) and Diffuse irradiance in $W.m^{-2}$
- WMO sunshine threshold: $120 W.m^{-2}$ direct beam
- DNI (Direct Normal Irradiance) calculations
- Sunshine status
- No moving parts, shade rings or motorized tracking

PROs

- High frequency measurements (sec. to min.)
- Higher accuracy, if properly managed

Cons

- Limited geographical representation
- Limited time availability
- Costs for acquisition and operation
- Regular maintenance and calibration
- Data quality control




- 1 Site Preliminary Analysis
- 2 Conceptual Design
- 3 Mitigation of Energy Losses



Conceptual Design

Basic scheme of the conceptual design





Conceptual Design


Input, design parameters and output





Conceptual Design

Grid connected PV plant - Equipments






Conceptual Design

PV modules disposition – Array Sizer




The PV module can be placed in several configurations:



It is strongly dependent on the **Occupation ratio** = the rate between the land area and the DC capacity [ha/MW]

PV module technology (mono, poly, thin film, BiFi) – *efficiency?*
Module parameters?

Occupation ratio vs GCR



Perimeter of the area (w/o troubled area) *fitting?*

Maximum system voltage
1000/1500Vdc

How many # of modules per string

Array Sizer tool

Inputs


- PV Module selection
Voc, Isc, α, β, γ
- Maximum system voltage
1000/1500Vdc
- Maximum system current
2000A
- Historical Time-series
GHI, T_{amb} over 20years

max. of module per string



Conceptual Design

Layout – Spacing between rows and GCR



$GCR^{-1} \uparrow$ then EOH \uparrow but also CapEX \uparrow
 $GCR^{-1} \downarrow$ then CapEX \downarrow but also EOH \downarrow

Most used GCR^{-1} are between 1,75/2 and 3,5. Below 1,75 is too short the distance between the trackers and from the O&M(you) is not accepted. Above 3,5 the gain in the energy production doesn't justify the capex increasing, because is too high.

GCR^{-1}

The inverse of the Ground Covered Ratio is the total area occupied by the PV system divided by the area of the PV Modules


For NS tracking structures

$$GCR^{-1} = \frac{Pitch_{EW \text{ direction}}(B)}{Width_{EW \text{ direction}}(A)}$$


For fixed structures

$$GCR^{-1} = \frac{Pitch_{NS \text{ direction}}(B)}{Width_{NS \text{ direction}}(A)}$$

CapEX vs GCR



EOH vs GCR





Conceptual Design

Configuration – DC/AC Ratio



DC/AC ratio is the relationship between: DC array's nameplate power at STC to the inverter AC output power

When **DC**↑ and **AC** is constant:

- The generation profile increase (green curve);
- The peak power is clipped over the rated power of the inverters;
- The energy gained through the oversizing of DC is the green;
- The energy lost during the power limiting is the gray.





Figure 1a: Daily Production Profile Power Limiting Day



Conceptual Design

Configuration – DC/AC Ratio





Conceptual Design


Configuration – DC/AC Ratio




LCOE driver:

DC/AC ↑ then EOH ↓ but also CapEX ↓

CapEX vs DC/AC ratio



EOH vs DC/AC ratio





Conceptual Design

Best configuration and equipment selection – LCoE Minimization




$$LCoE = \frac{CapEX + \sum_{i=1}^N \frac{OpEX}{(1+r)^i}}{\sum_{t=1}^N \frac{e_t}{(1+r)^t}}$$

$$\left\{ \begin{array}{l} r = \text{Discount rate} \\ e_t = \text{Specific energy yield} \left[\frac{kWh}{kWp} \right] \\ N = \text{Lifetime [years]} \end{array} \right.$$


Which is the optimal engineering solution:

↑ or ↓ GCR ??
↑ or ↓ DC/AC??




Minimum LCOE

LCOE vs DC/AC



LCOE vs GCR



		LCOE																				
		1.20																				
GCR	DC/AC	LCOE																				
		1.00	1.01	1.02	1.03	1.04	1.05	1.06	1.07	1.08	1.09	1.10	1.11	1.12	1.13	1.14	1.15	1.16	1.17	1.18	1.19	1.20
1.00	1.00	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30
1.01	1.01	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30
1.02	1.02	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30
1.03	1.03	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30
1.04	1.04	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30
1.05	1.05	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30
1.06	1.06	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30
1.07	1.07	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30
1.08	1.08	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30
1.09	1.09	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30
1.10	1.10	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30
1.11	1.11	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30
1.12	1.12	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30
1.13	1.13	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30
1.14	1.14	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30
1.15	1.15	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30
1.16	1.16	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30
1.17	1.17	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30
1.18	1.18	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30
1.19	1.19	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30
1.20	1.20	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30	32.30

$$LCoE = \frac{Capex + \sum_{i=1}^N \frac{Opex_i}{(1+r)^i}}{\sum_{t=1}^N \frac{e_t}{(1+r)^t}}$$

$$\left\{ \begin{array}{l} r = \text{Discount rate} \\ e_t = \text{Specific energy yield [kWh/kWp]} \\ N = \text{Lifetime [years]} \end{array} \right.$$




Conceptual Design

Conceptual Design Output – Energy production at 1st year (P50)



TMY, layout information,
PV module parameters,
inverter characteristics,
DC and AC capacity,
soiling, mismatch,
wiring, aux
consumption,..ect



+ HV losses
+ system availability

5 - Energy Production Assessment - Results	
DC - Plant Capacity [MW]	35.20
AC - Inverter Capacity at 50 °C[MW]	36.66
AC - Inverter Capacity at 25 °C[MW]	38.95
AC - Maximum achieved power at the delivery point	37.86
P50 for comparative purpose	
P50 - EOH downstream the inverter, <u>1st year</u>	3495
P50 - EOH fed into the grid, <u>1st year</u>	3434
P50 - Load factor fed into the grid = EOH/8760, <u>1st year</u>	39.20%
P50 - Net Capacity Factor (NCF) fed into the grid = (EOH x DC/AC_ratio)/8760, <u>1st year</u>	37.63%
Recommended values by Solar CoE according to the uncertainty level	
Pxx recommended	P50
=> Combined uncertainty, simulation + solar resource data (1 year)	8.10%
=> Combined uncertainty, simulation + solar resource data (1 years)	8.10%
Pxx - EOH downstream the inverter, <u>1st year</u>	3495
Pxx - EOH fed into the grid, <u>1st year</u>	3434
Pxx - Load factor fed into the grid = EOH/8760, <u>1st year</u>	39.20%
Pxx - Net Capacity Factor (NCF) fed into the grid = (EOH x DC/AC_ratio)/8760, <u>1st year</u>	37.63%
Pxx - Energy production fed into the grid, <u>1st year</u> [GWh]	120.8504
Pxx - Average yearly performance ratio (PR) fed into the grid	82.18%
P90 for information purpose	
P90 - EOH downstream the inverter, <u>1st year</u>	3132
P90 - EOH fed into the grid, <u>1st year</u>	3077
P90 - Load factor fed into the grid = EOH/8760, <u>1st year</u>	35.13%
P90 - Net Capacity Factor (NCF) fed into the grid = (EOH x DC/AC_ratio)/8760, <u>1st year</u>	33.72%




Conceptual Design

Conceptual Design Output – Energy production over lifetime plant.



We start from the energy production at first year and we apply:

Year	Total Plant Availability (%)
1	98.00%
2	98.50%
3	99.00%
4	99.00%
> 5-20	99.00%
>20	98.00%





1

Site Preliminary Analysis

2

Conceptual Design

3

Mitigation of Energy Losses



Mitigation of Energy Losses

Energy Losses – Table



DC side losses	Tracker	Transposition Factor
		Shading (mutual)
	Far Shading	Far shading loss (horizon)
	PV Module	IAM factor on global
		LID
		Annual Degradation
		PV loss due to irradiance level
	Soiling	PV loss due to temperature
Soiling	Soiling	
Mismatching losses	Mismatching losses	
DC Cables	Yearly average DC side cable losses in operating conditions	
AC side losses	Inverter	Yearly average inverter loss in operation (efficiency)
		Inverter loss over nominal power (clipping)
	AC Cables	Yearly average AC side cable losses in operating conditions
	Transformers	Yearly average transformer losses in operating conditions
	Transmission	Transmission line losses
PPC	POC (Point of Connection) power limitation losses	
Other and auxiliaries losses	Auxiliaries	Auxiliary consumption
	Internal Availability	Internal Availability
	External Availability	Grid Availability




Mitigation of Energy Losses

Energy Losses – Shading losses




Far shading



Avoid Beam shading:
Backtracking mode



Near shading






Mitigation of Energy Losses

Energy Losses – Soiling Losses



Module technology (c-Si/Thin Film?)	c-Si
Environment (1-4, 1=Clean, 4=~Quarry)	3
Longest dry period (1-12, in months)	6
# of similar dry periods per year	1
# of manual cleaning/year (0-11)	2
% of losses in non dry period	25%
Annual soiling losses <u>without cleaning</u>	6.50%
Annual soiling losses <u>with cleaning</u>	4.18%


Frequency and intensity of the rainfall



Synthesis of data (average daily % of losses for dry day)

Conditions	Daily soiling losses rate
Clean environment & No activity	~0.01%/dry day
Clean environment & small road	0.02-0.03%/dry day
Metropolitan, Highway, pollution	0.04-0.07%/dry day
Desert	0.1-0.2%/dry day
Desert + Activity/Pollution	0.2-0.3%/dry day

The soiling losses impacts are not linear





Mitigation of Energy Losses

Energy Losses – Clipping Losses



When **DC**↑ and **AC** is constant:

- The peak power is clipped over the rated power of the inverters;
- The energy lost during the power limiting is the gray.

Clipping normally less than 1-2%.

To reduce clipping → # CU (inverter) ↑

Algorithm evaluate the best DC/AC ratio to minimize losses.





Figure 1a: Daily Production Profile Power Limiting Day



Recap and Best Practice

System Design Software



LRA: Layout Research Algorithm

This module, given a set of main equipments, has the function of exploring many possible system configurations, in order to minimize LCOE. Each system configuration is described by an “admissible” combination of values of the three most important layout parameters:

- Ground Covering Ratio
- DC size
- DC/AC ratio

Best Configuration

SREA – GTS – Civil and EM BoQ – Layout drawing



GLOBAL OPTIMIZATION OF
INTEGRATED **PHOTOVOLTAIC** SYSTEM
FOR LOW ELECTRICITY COST



This project has received funding from the European Union's Horizon 2020 research and innovation programme under grant agreement No 792059

Thank you for your attention!

Follow us

